

Notice

TSP Name: Gulf South Pipeline Company, LLC

TSP: 78444247

Category: Critical

Post Date/Time: 03/25/2025 06:39:22PM

Notice Type Desc: Other

Notice Effective Date/Time: 03/25/2025 06:40:00PM

Notice Stat Desc: Initiate

Notice End Date/Time: 03/28/2025 09:00:00 AM

Notice ID: 5036253

Response Date/Time:

Prior Notice:

Critical: Y

Reqrd Rsp Desc: No response required

Subject: Force Majeure Update – March 24, 2025, Weather Incident at Stratton Ridge

Notice Text: Gulf South Pipeline Company, LLC (Gulf South) wishes to provide the following update concerning the Force Majeure Notice posted at 9:59 AM March 24, 2025:

Following a thorough inspection of Meter 24329 - Stratton Ridge (to FLNG) and ancillary equipment on the Coastal Bend Header, Gulf South has concluded its facilities did not suffer a lightning strike nor a Force Majeure event the morning of March 24, 2025. The disruption in flow experienced at approximately 2:50 AM was the result of weather-related impact to downstream third-party facilities. The instantaneous loss of flow through the meter caused a sudden increase in line pressure and resulted in Gulf South's Over Pressure Protection valve closing to protect facility integrity.

Please contact your Customer Service Representative with any questions.